

# THE CITY OF COOPER

91 North Side Square • Cooper, Texas 75432  
<http://cityofcoopertx.municipalimpact.com>

Darren Braddy  
Mayor

Office 903-395-4433  
Fax 903-395-0377

## Mandatory Language for Surface Water Treatment Technique Violation

### SURFACE WATER TREATMENT TECHNIQUE

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. You do not need to use an alternative water supply.

The **CITY OF COOPER**, PWS ID **TX0600001**, failed to meet the minimum treatment technique requirements for the month of **FEBRUARY 2021**. Specifically, our water system had:

- Low Disinfection Contact Time (CT) for more than four consecutive hours, and
- More than 5% of the combined filter effluent turbidity readings were above 0.3 NTU for the month.

The **CITY OF COOPER**, PWS ID **TX 0600001**, has corrected this violation. This happened during the winter storm and was due to the uncontrollable power outage. The city was already under a boil water notice at that time.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact **TERRY PALMER**  
**903-272-0158**

Posted /Delivered on: **May 25, 2021**

